

Testing of Air Filter according to ISO 16890:2016 (6 appendices)

A test according to ISO 16890:2016 was carried out by request from

Tested item

YD/7, a 592 mm x 592 mm x 48 mm, Panel filter.

Pictures can be found in appendix 5.

The item was sent to RISE t, z o.o. and was received by RISE on
June 21, 2018.

The item was without visible defects.

Test method

The test was carried out according to standard ISO 16890:2016 "Air filters for general ventilation". The standard consists of four parts:

- ISO 16890-1: *Technical specifications, requirements and classification system based upon particulate matter efficiency (ePM)*

- ISO 16890-2: *Measurement of fractional efficiency and air flow resistance*

Measurements were performed with dual particle counters according to section 9.3.4 - Testing sequence for dual OPC testing.

- ISO 16890-3: *Determination of the gravimetric efficiency and the airflow resistance versus the mass of test dust captured*

RISE Research Institutes of Sweden AB

Postal address
Box 857
SE-501 15 BORÅS
Sweden

Office location
Brinellgatan 4
SE-504 62 BORÅS

Phone / Fax / E-mail
+46 10 516 50 00
+46 33 13 55 02
info@ri.se

This report may not be reproduced other than in full, except with the prior written approval of the issuing laboratory.



Accred. No. 1002
Testing
ISO/IEC 17025

- ISO 16890-4: Conditioning method to determine the minimum fractional test efficiency

Eight cabinets with a total surface area of 1.82 m² were placed in the chamber according to ISO 16890-4 section 7. The purity of the 2-propanol was 99.5 %. The test item was conditioned for 24.5 +/- 0.5 hours.

Efficiency at 50% nominal air flow was measured with DEHS in the range 0.3 – 1 µm.

Deviation from the standard:

Section 9.2.2 and 9.2.8, the evaporated amount of 2-propanol was not determined. The temperature and humidity was not recorded during the discharge procedure.

Date and Place

The test was carried out at RISE's laboratory of Energy and circular economy in Borås, Sweden on July 6 – August 6, 2018.

Tests according to ISO 16890-2 were carried out on July 6, 2018.

Tests according to ISO 16890-3 were carried out on August 6, 2018.

Tests according to ISO 16890-4 were carried out on July 20, 2018. Conditioning procedure according to ISO 16890-4 was carried out on July 09-10, 2018.

Results

The results are presented in appendix 1-4 and are valid only for the item tested.

In appendix 1 a summary of the results are reported according ISO 16890-1. It also includes the fractional efficiencies and the calculation of PM-efficiencies.

In appendix 2 fractional efficiency and air flow resistance are reported according to ISO 16890-2.

In appendix 3 determination of the gravimetric efficiency (arrestance) and the air flow resistance versus the mass of test dust capture (test dust capacity) are reported according to ISO 16890-3.

In appendix 4 the minimum fractional efficiency is reported according to ISO 16890-4.

The measured particle concentrations are reported in appendix 2 and appendix 4. Table A6 (upstream count data), A7 (downstream count data) and A9 Uncertainty in ISO 16890-2 Annex A are reported.

Measurement equipment

- Pressure gauge Furness model 318, RISE's inventory no. 901 568 (static P Filter)
- Pressure gauge Furness model 318, RISE's inventory no. 901 569 (static P Flow)
- Pressure gauge Furness FC012, RISE's inventory no. 201 691 (ΔP Filter)
- Pressure gauge Furness FC012, RISE's inventory no. 201 690 (ΔP Flow)
- Particle counter TSI, OPS 3330, RISE's inventory no. 902240
- Particle counter TSI, OPS 3330, RISE's inventory no. 902241
- Barometer, Testo 511, RISE's inventory no. 900 078
- Temperature and RH, Testo 635, RISE's inventory no. 900 065
- Weighing scale, Kern EMS6K0.1, RISE's inventory no. BX81724
- Flow meter, MFS-C-250, RISE's inventory no. 202 742
- Temperature and RH, Tinytag, DIV 94 S
- Barometer, Druck PACE 1001, RISE's inventory no. 902243

Uncertainty of measurement

The uncertainty of the Air flow is better than $\pm 5\%$

The uncertainty of the Pressure Drop is better than $\pm 3\%$

The uncertainty of the Temperature is better than $\pm 0.5\text{ }^{\circ}\text{C}$

The uncertainty of the Relative Humidity is better than $\pm 2\%$ RH

The uncertainty of the Atmospheric Pressure is better than $\pm 1\text{ mbar}$

The uncertainty of the Measured mass is better than $\pm 0.5\text{ g}$

The uncertainty has been calculated according to EA-4/16 with a coverage factor $k=2$.

The uncertainty of the filtration efficiency according to ISO 16890:2016 is presented in appendices 2 and 4.

RISE Research Institutes of Sweden AB Energy and circular economy - Sustainable energysystems

Performed by

Examined by



Signed by: Ingmar Schuessler
Reason: I am the author of this document
Date & Time: 2018-08-17 09:49:12 +02:00



Signed by: Tobias Eriksson
Reason: I have reviewed this document
Date & Time: 2018-08-15 16:47:41 +02:00

Ingmar Schüßler

Tobias Eriksson

Appendices

1. Summary test report according to ISO 16890-1:2016
2. Test report according to ISO 16890-2:2016
3. Test report according to ISO 16890-3:2016
4. Test report according to ISO 16890-4:2016
5. Additional pictures of the test item.
6. The interpretation of test reports

Appendix 1

ISO 16890-1:2016 - Air Filter Test Results				Testing Organization:	
				RISE Research Institutes of Sweden AB Brinellgatan 4, 501 15 Borås, Sweden +460105165000	
GENERAL					
Report no.: 8P04418-01E		Date of tests: 2018-07-06 - 2018-08-06		Date of report: 2018-08-15	
Supervisor: CM			Device obtained (when and how obtained):		
Test(s) requested by:			The device was sent and obtained on 2018-06-21		
DEVICE TESTED					
Model: LYD/7		Manufacturer:		Construction: Panel filter	
Article number: -		Type of medium: Glass		Net effective filtering area: 5.6 m ²	
				Filter dimensions (width x height x depth) 592x592x48 mm	
TEST DATA AND ATTACHED TEST REPORTS					
Test air flow rate: 0.472 m ³ /s		Test aerosol: KCl (1-10 µm)		Test report to ISO 16890-2	
		DEHS (0.3-1 µm)		Test report to ISO 16890-3	
				Test report to ISO 16890-4	
				Report no. 8P04418-01E Appendix 2	
				Report no. 8P04418-01E Appendix 3	
				Report no. 8P04418-01E Appendix 4	
RESULTS					
Initial pressure differential: 79 Pa		Initial grav. arresstance: >99 %		ePM _{1, min} 60 %	
				ePM _{2.5, min} 70 %	
Final test pressure differential: 300 Pa		Test dust capacity: 124 g		ISO rating (1700 m ³ /h)	
				ISO ePM ₁ 60 %	
				ePM ₁ 60 %	
				ePM _{2.5} 70 %	
				ePM ₁₀ 90 %	
Remarks:					
<p>The figure contains two graphs. The top graph plots Fractional efficiency (%) on the y-axis (0 to 100) against Particle size (µm) on the x-axis (0.1 to 10.0). It shows three data series: Initial fractional efficiency E_i (ISO 16890-2) as a blue line with circles, Conditioned fractional efficiency E_{D,i} (ISO 16890-4) as a red line with squares, and Average fractional efficiency E_{A,i} (ISO 16890-1) as a green line with triangles. All series show an increasing trend from approximately 50% at 0.2 µm to nearly 100% at 10 µm. The bottom graph plots Pressure differential (Pa) on the left y-axis (0 to 400) and Arrestance (%) on the right y-axis (0 to 100) against Air flow rate (m³/s) on the x-axis (0.0 to 0.7). It shows three data series: Pressure differential as a function of air flow rate (clean filter) (ISO 16890-2) as a blue line with circles, Pressure differential as a function of test dust captured (ISO 16890-3) as a red line with squares, and Grav. arresstance as a function of test dust captured (ISO 16890-3) as a green line with triangles. The blue line shows a slight increase in pressure differential with air flow rate. The red line shows a significant increase in pressure differential as test dust captured increases. The green line shows a constant grav. arresstance of approximately 100% across the range of test dust captured.</p>					
NOTE: The results of this test relate only to the test device in the condition stated herein. The performance results cannot by themselves be quantitatively applied to predict filtration performance in all "real life" environments.					

Appendix 1

ISO 16890-1:2016 - Fractional efficiency values							
Testing organisation: RISE Research Institutes of Sweden AB				Report no: 8P04418-01E			
Model: LYD/7				Manufacturer: <i>Carroll</i> J. O			
Test air flow rate: 0.472 m ³ /s				Date of report: 2018-08-15			
<i>i</i>	<i>d_i</i> µm	<i>d_{i+1}</i> µm	<i>d_{a,i}</i> µm	$\Delta \ln d_i$ µm	<i>E_i</i> %	<i>E_{D,i}</i> %	<i>E_{A,i}</i> %
1	0.30	0.40	0.35	0.29	48.6	48.9	48.8
2	0.40	0.55	0.47	0.32	57.8	57.6	57.7
3	0.55	0.70	0.62	0.24	66.3	66.8	66.6
4	0.70	1.00	0.84	0.36	76.0	75.9	76.0
5	1.00	1.30	1.14	0.26	87.5	87.4	87.4
6	1.30	1.60	1.44	0.21	89.8	90.4	90.1
7	1.60	2.20	1.88	0.32	93.9	93.6	93.8
8	2.20	3.00	2.57	0.31	98.0	97.9	97.9
9	3.00	4.00	3.46	0.29	99.4	99.4	99.4
10	4.00	5.50	4.69	0.32	99.7	99.7	99.7
11	5.50	7.00	6.20	0.24	99.8	99.7	99.7
12	7.00	10.00	8.37	0.36	99.9	99.8	99.8

d_i: Lower limit particle diameter in a size range *i*, µm

d_{i+1}: Upper limit particle diameter in a size range *i*, µm

d_{a,i}: Geometric mean diameter of a size range *i*, µm

$\Delta \ln d_i$: Logarithmic width of a particle diameter size in range *i*; ln is the natural logarithm to the base of *e*, where *e* is an irrational and transcendental constant approximately equal to 2.718281828, dimensionless
 $\Delta \ln d_i = \ln (d_{i+1}/d_i)$

E_i: Initial fractional efficiency of particle size range *i* of the untreated and unloaded filter element, %

E_{D,i}: Fractional efficiency of particle size range *i* of the filter element after an artificial conditioning step, %

E_{A,i}: Average fractional efficiency $(E_i + E_{D,i})/2$ of particle size range *i*, %

Appendix 1

ISO 16890-1:2016 - Calculation of PM-efficiencies								
Testing organisation: RISE Research Institutes of Sweden AB						Report no.: 8P04418-01E		
Model: LYD/7						Manufacturer:		
Test air flow rate: 0.472 m ³ /s						Date of report: 2018-08-15		
<i>i</i>	$d_{a,i}$ µm	$\Delta \ln d_i$ µm	urban distribution $q_{3u}(d_{a,i})$	$q_{3u}(d_{a,i}) \cdot \Delta \ln d_i$	$E_{D,i} \cdot q_{3u}(d_{a,i}) \cdot \Delta \ln d_i$	$E_{A,i} \cdot q_{3u}(d_{a,i}) \cdot \Delta \ln d_i$	ePM _{x, min} %	ePM _x %
1	0.35	0.29	0.226	0.065	3.186	3.18	ePM _{1, min}	ePM ₁
2	0.47	0.32	0.199	0.063	3.646	3.65		
3	0.62	0.24	0.158	0.038	2.553	2.54		
4	0.84	0.36	0.115	0.041	3.119	3.12		
Σ line 1-4				0.208	12.504	12.494	60	60
5	1.14	0.26	0.085	0.022	1.950	1.951	ePM _{2.5, min}	ePM _{2.5}
6	1.44	0.21	0.076	0.016	1.430	1.425		
7	1.88	0.32	0.080	0.026	2.392	2.396		
8	2.57	0.31	0.100	0.031	3.032	3.033		
Σ line 1-8				0.302	21.308	21.298	70	70

<i>i</i>	$d_{a,i}$ µm	$\Delta \ln d_i$ µm	rural distribution $q_{3r}(d_{a,i})$	$q_{3r}(d_{a,i}) \cdot \Delta \ln d_i$	$E_{A,i} \cdot q_{3r}(d_{a,i}) \cdot \Delta \ln d_i$	ePM _x %
1	0.35	0.29	0.094	0.027	1.321	ePM ₁₀
2	0.47	0.32	0.084	0.027	1.542	
3	0.62	0.24	0.074	0.018	1.193	
4	0.84	0.36	0.070	0.025	1.900	
5	1.14	0.26	0.076	0.020	1.750	
6	1.44	0.21	0.088	0.018	1.652	
7	1.88	0.32	0.108	0.034	3.226	
8	2.57	0.31	0.137	0.043	4.170	
9	3.46	0.29	0.167	0.048	4.778	
10	4.69	0.32	0.195	0.062	6.206	
11	6.20	0.24	0.217	0.052	5.213	
12	8.37	0.36	0.231	0.083	8.242	
Σ line 1-12				0.457	41.193	90

Appendix 2

ISO 16890-2:2016 - AIR FILTER TEST RESULTS SUMMARY				Testing Organization: RISE Research Institutes of Sweden AB Brinellgatan 4, 501 15 Borås, Sweden +460105165000		
GENERAL						
Test ID: SP201807061		Date of test: 2018-07-06		Operator: CM		
Particle counter information			Air flow measurement:		Device obtained (when and how obtained):	
Manufacturer: TSI Gmbh	Model: OPS 3330	Coincidence value (p/cm ³): 300	Annubar, Micatrone Air flow sensor MFS-SS		The device was sent and obtained on 2018-06-21	
DEVICE TESTED						
Model: LYD/7		Manufacturer:		Construction: Panel filter		
Article number: -	Type of media: Glass	Net effective media area (m ²): 5.6 m ²		Filter dimensions (width x height x depth) 592x592x48 mm		
Filter/media electrostatic charge: No		Media colour: white		Media adhesive: N/A		
Device Condition:		Clean / Initial				
Other descriptive information:						
TEST DATA SUMMARY						
Test air flow rate: 0.472 m ³ /s		Test air temperature: 22.3 - 22.7 ° C		Test air RH: 45.9 - 49.7 %		Test aerosol: DEHS (0.3-1 µm) KCl (1-10 µm)
RESULTS						
Resistance to airflow (Pa)			Fractional Efficiency (%)			
Measured:	79 Pa	Rated initial: -	Range (µm)	Measured Efficiency	Rated Efficiency	Upstream concentration (particles / dm ³)
		Rated Final: -				
Test Device Photo			0.30 - 0.40	49		18705
			0.40 - 0.55	58		16065
			0.55 - 0.70	66		9640
			0.70 - 1.00	76		10623
			1.00 - 1.30	87		9517
			1.30 - 1.60	90		5133
			1.60 - 2.20	94		20887
			2.20 - 3.00	98		12795
			3.00 - 4.00	99		6180
			4.00 - 5.50	100		3489
			5.50 - 7.00	100		991
			7.00 - 10.00	100		754
Remarks:						
NOTE: The results of this test relate only to the test device in the condition stated herein. The performance results cannot by themselves be quantitatively applied to predict filtration performance in all "real life" environments.						

Appendix 2

ISO 16890-2:2016 - AIR FILTER TEST RESULTS DETAILS		Testing Organization: RISE Research Institutes of Sweden AB Brinellgatan 4, 501 15 Borås, Sweden +460105165000																					
Test ID: SP201807061	Date of test: 2018-07-06	Operator: CM																					
TEST DATA DETAILS																							
Resistance to Airflow 1.2 kg/m³																							
% of rated airflow	Airflow (m ³ /s)	Resistance to Airflow (Pa)	<table border="1"> <caption>Data for Resistance to Airflow Graph</caption> <thead> <tr> <th>Airflow (m³/s)</th> <th>Resistance to Airflow (Pa)</th> </tr> </thead> <tbody> <tr><td>0.189</td><td>29</td></tr> <tr><td>0.234</td><td>37</td></tr> <tr><td>0.353</td><td>57</td></tr> <tr><td>0.472</td><td>79</td></tr> <tr><td>0.590</td><td>101</td></tr> </tbody> </table>	Airflow (m ³ /s)	Resistance to Airflow (Pa)	0.189	29	0.234	37	0.353	57	0.472	79	0.590	101								
Airflow (m ³ /s)	Resistance to Airflow (Pa)																						
0.189	29																						
0.234	37																						
0.353	57																						
0.472	79																						
0.590	101																						
40%	0.189	29																					
50%	0.234	37																					
75%	0.353	57																					
100%	0.472	79																					
125%	0.590	101																					
Fractional Efficiency by Particle Size																							
<table border="1"> <caption>Data for Fractional Efficiency Graph</caption> <thead> <tr> <th>Particle size (µm)</th> <th>Fractional efficiency (%)</th> </tr> </thead> <tbody> <tr><td>0.3</td><td>48</td></tr> <tr><td>0.4</td><td>58</td></tr> <tr><td>0.6</td><td>68</td></tr> <tr><td>1.0</td><td>88</td></tr> <tr><td>1.5</td><td>90</td></tr> <tr><td>2.5</td><td>95</td></tr> <tr><td>4.0</td><td>98</td></tr> <tr><td>6.0</td><td>98</td></tr> <tr><td>10.0</td><td>98</td></tr> </tbody> </table>				Particle size (µm)	Fractional efficiency (%)	0.3	48	0.4	58	0.6	68	1.0	88	1.5	90	2.5	95	4.0	98	6.0	98	10.0	98
Particle size (µm)	Fractional efficiency (%)																						
0.3	48																						
0.4	58																						
0.6	68																						
1.0	88																						
1.5	90																						
2.5	95																						
4.0	98																						
6.0	98																						
10.0	98																						
<p>NOTE: The results of this test relate only to the test device in the condition stated herein. The performance results cannot by themselves be quantitatively applied to predict filtration performance in all "real life" environments.</p>																							

Appendix 2

Efficiency measurement
Upstream count data

OPC bin	$d_{a,i}$	Upstream efficiency count data					
	μm	1	2	3	4	5	$U_{e,tot}$
1	0.35	18875	18351	18826	18875	18600	93527
2	0.47	16158	15927	16043	16319	15880	80327
3	0.62	9734	9424	9561	9781	9698	48198
4	0.84	10821	10348	10716	10633	10596	53114
5	1.14	8823	9518	9571	9358	10314	47584
6	1.44	4788	5140	5056	4946	5735	25665
7	1.88	19636	21275	21050	19859	22614	104434
8	2.57	12122	13001	12997	12193	13663	63976
9	3.46	5763	6389	6282	5867	6601	30902
10	4.69	3265	3561	3553	3364	3703	17446
11	6.20	930	1016	1018	960	1032	4956
12	8.37	793	777	770	689	739	3768

Note: All data shown is the number of particle counts for 60 s

Efficiency measurement
Downstream count data

OPC bin	$d_{a,i}$	Downstream efficiency count data					
	μm	1	2	3	4	5	$D_{e,tot}$
1	0.35	9327	9330	9605	9669	9443	47374
2	0.47	6809	6966	6950	6901	6822	34448
3	0.62	3285	3260	3155	3186	3241	16127
4	0.84	2571	2462	2492	2558	2501	12584
5	1.14	1142	1309	1269	1199	1354	6273
6	1.44	571	631	607	586	634	3029
7	1.88	1240	1274	1316	1218	1415	6463
8	2.57	259	266	279	263	301	1368
9	3.46	35	46	33	42	40	196
10	4.69	8	9	11	12	13	53
11	6.20	3	1	3	6	0	13
12	8.37	1	1	0	2	4	8

Note: All data shown is the number of particle counts for 60 s

Efficiency measurement
Final results and uncertainty

OPC bin	$d_{a,i}$ μm	Penetration data reduction			Uncertainty limits		Uncertainty	Efficiency
		P_a	δ	e	Static	Dynamic	Pass/Fail	%
1	0.35	0.514	0.010	0.012	≤ 0.05	0.036	Pass	48.6
2	0.47	0.422	0.008	0.010	≤ 0.05	0.030	Pass	57.8
3	0.62	0.337	0.009	0.011	≤ 0.05	0.024	Pass	66.3
4	0.84	0.240	0.005	0.006	≤ 0.05	0.017	Pass	76.0
5	1.14	0.125	0.004	0.004	≤ 0.05	0.009	Pass	87.5
6	1.44	0.102	0.004	0.005	≤ 0.05	0.007	Pass	89.8
7	1.88	0.061	0.001	0.002	≤ 0.05	0.004	Pass	93.9
8	2.57	0.020	0.001	0.001	≤ 0.05	0.001	Pass	98.0
9	3.46	0.006	0.001	0.001	≤ 0.05	0.001	Pass	99.4
10	4.69	0.003	0.000	0.001	≤ 0.05	0.000	Pass	99.7
11	6.20	0.002	0.002	0.002	≤ 0.05	0.000	Pass	99.8
12	8.37	0.001	0.001	0.002	≤ 0.05	0.000	Pass	99.9

$d_{a,i}$: Geometric mean diameter of a size range i , μm
 P_a : the final penetration for a given particle size
 δ : the standard deviation of the penetration for a given particle size
 e : the uncertainty of the penetration for a given particle size

Appendix 3

ISO 16890-3:2016 - AIR FILTER TEST RESULTS SUMMARY				Testing Organization RISE Research Institutes of Sweden AB Brinellgatan 4, 501 15 Borås, Sweden +460105165000	
GENERAL					
Test ID: SP201807061		Date of test: 2018-08-06		Operator: CM	
		Air flow measurement: Annubar, Micatrone Air flow sensor MFS-SS		Test sample obtained: The device was sent and obtained on 2018-06-21	
DEVICE TESTED					
Model: LYD/7		Manufacturer:		Construction: Panel filter	
Article number: -	Type of media: Glass	Net effective media area (m ²) 5.6 m ²		Filter dimension (width x height x depth) 592x592x48 mm	
Filter/media electrostatic charge: No		Media colour: white		Media adhesive: N/A	
Device Condition: Conditioned per ISO 16890-4					
Other descriptive information:					
TEST DATA SUMMARY					
Test air flow rate: 0.472 m ³ /s		Test air temperature: 24.2 - 24.6 °C		Test air RH: 36.2 - 37 %	
Loading dust: Particle Technology, ISO 121031 A2-fine					
RESULTS					
Resistance to airflow			Dust loading results		
Measured: 78 Pa	Rated initial: - Pa		Initial arestance (%)	Average arestance(%)	Test dust capacity (g)
Final test pressure: 300 Pa	Rated Final: - Pa		>99 %	>99 %	124 g
Test Device Photo					
Remarks:					
NOTE: The results of this test relate only to the test device in the condition stated herein. The performance results cannot by themselves be quantitatively applied to predict filtration performance in all "real life" environments.					

Appendix 3

ISO 16890-3:2016 - AIR FILTER TEST RESULTS DETAILS			Testing Organization:		
			RISE Research Institutes of Sweden AB Brinellgatan 4, 501 15 Borås, Sweden +460105165000		
Test ID:	SP201807061	Date of test:	2018-08-06	Operator:	CM
TEST DATA DETAILS					
Resistance to Airflow 1.2 kg/m ³					
% of rated airflow	Airflow (m ³ /s)	Resistance to Airflow (Pa)			
40%	0.189	29			
50%	0.235	37			
75%	0.355	58			
100%	0.472	78			
125%	0.591	99			
<p>NOTE: The results of this test relate only to the test device in the condition stated herein. The performance results cannot by themselves be quantitatively applied to predict filtration performance in all "real life" environments.</p>					

Appendix 4

ISO 16890-4:2016 - AIR FILTER TEST RESULTS SUMMARY			Testing Organization: RISE Research Institutes of Sweden AB Brinellgatan 4, 50115 Borås, Sweden +460105165000			
GENERAL						
Test ID: SP201807061		Date of test: 2018-07-20		Operator: CM		
Particle counter information			Air flow measurement:		Device obtained (when and how obtained): The device was sent and obtained on 2018-06-21	
Manufacturer: TSI Gmbh	Model: OPS 3330	Coincidence value (p/cm ³): 300	Annubar, Micatrone Air flow sensor MFS-SS			
DEVICE TESTED						
Model: LYD/7		Manufacturer:		Construction: Panel filter		
Article number: -	Type of media: Glass	Net effective media area (m ²): 5.6 m ²		Filter dimensions (width x height x depth): 592x592x48 mm		
Filter/media electrostatic charge: No		Media colour: white		Media adhesive: N/A		
Device Condition: Conditioned per ISO 16890-4						
Other descriptive information:						
TEST DATA SUMMARY						
Test air flow rate: 0.472 m ³ /s		Test air temperature: 22 - 23.8 ° C		Test air RH: 41.8 - 50.4 %		
Test aerosol: DEHS (0.3-1 µm) KCl (1-10 µm)						
RESULTS						
Resistance to airflow (Pa)			Fractional Efficiency (%)			
Measured: 78 Pa	Rated initial: -	Rated Final: -	Range (µm)	Measured Efficiency	Rated Efficiency	Upstream concentration (particles / dm ³)
Test item photo			0.30 - 0.40	49		13631
			0.40 - 0.55	58		11805
			0.55 - 0.70	67		7257
			0.70 - 1.00	76		7973
			1.00 - 1.30	87		4717
			1.30 - 1.60	90		2566
			1.60 - 2.20	94		10521
			2.20 - 3.00	98		6619
			3.00 - 4.00	99		3319
			4.00 - 5.50	100		2020
			5.50 - 7.00	100		643
7.00 - 10.00	100		569			
Remarks:						
NOTE: The results of this test relate only to the test device in the condition stated herein. The performance results cannot by themselves be quantitatively applied to predict filtration performance in all "real life" environments.						

Appendix 4

ISO 16890-4:2016 - AIR FILTER TEST RESULTS DETAILS			Testing Organization: RISE Research Institutes of Sweden AB Brinellgatan 4, 501 15 Borås, Sweden +460105165000		
Test ID: SP201807061	Date of test: 2018-07-20	Operator: CM			
TEST DATA DETAILS					
Resistance to Airflow, 1.2 kg/m ³		Fractional efficiency			
Initial		Range (µm)	E _i , 100 % nominal air flow	E _d , 100% nominal air flow	E _d , 50% nominal air flow
Airflow (m ³ /s)	Resistance to Airflow (Pa)				
0.189	29	0.30 - 0.40	48.6	48.9	50.3
0.234	37	0.40 - 0.55	57.8	57.6	58.6
0.353	57	0.55 - 0.70	66.3	66.8	65.5
0.472	79	0.70 - 1.00	76.0	75.9	73.8
0.590	101	1.00 - 1.30	87.5	87.4	
Conditioned		1.30 - 1.60	89.8	90.4	
Airflow (m ³ /s)	Resistance to Airflow (Pa)	1.60 - 2.20	93.9	93.6	
0.189	29	2.20 - 3.00	98.0	97.9	
0.235	37	3.00 - 4.00	99.4	99.4	
0.355	58	4.00 - 5.50	99.7	99.7	
0.472	78	5.50 - 7.00	99.8	99.7	
0.591	99	7.00 - 10.00	99.9	99.8	

CONDITIONING PROCEDURE			
Date: 2018-07-09 - 2018-07-10	Temperature in the chamber: n.a.	Relative humidity in the chamber: n.a.	Atmospheric pressure: 991.3 - 998.9 mbar

NOTE: The results of this test relate only to the test device in the condition stated herein. The performance results cannot by themselves be quantitatively applied to predict filtration performance in all "real life" environments.

Appendix 4

Efficiency measurement

Upstream count data

OPC bin	$d_{a,i}$	Upstream efficiency count data					
	μm	1	2	3	4	5	$U_{e,tot}$
1	0.35	13464	13751	13655	13579	13705	68154
2	0.47	11747	11812	11700	11830	11936	59025
3	0.62	7186	7434	7178	7155	7332	36285
4	0.84	8056	8100	7956	7905	7848	39865
5	1.14	4404	4958	4961	4583	4677	23583
6	1.44	2330	2807	2691	2548	2456	12832
7	1.88	9827	10844	11230	10135	10567	52603
8	2.57	6124	6991	7128	6403	6449	33095
9	3.46	3126	3489	3549	3127	3302	16593
10	4.69	1926	2032	2175	1955	2013	10101
11	6.20	621	692	672	622	606	3213
12	8.37	523	578	613	549	582	2845

Note: All data shown is the number of particle counts for 60 s

Efficiency measurement

Downstream count data

OPC bin	$d_{a,i}$	Downstream efficiency count data					
	μm	1	2	3	4	5	$D_{e,tot}$
1	0.35	6768	7094	7025	6966	7006	34859
2	0.47	4989	5342	5054	5163	5149	25697
3	0.62	2338	2461	2402	2495	2279	11975
4	0.84	1941	1878	1842	1891	1948	9500
5	1.14	621	626	703	589	628	3167
6	1.44	261	271	339	245	316	1432
7	1.88	663	650	746	663	657	3379
8	2.57	136	141	158	137	146	718
9	3.46	21	23	25	20	18	107
10	4.69	5	7	9	6	5	32
11	6.20	4	1	0	2	3	10
12	8.37	1	2	2	0	0	5

Note: All data shown is the number of particle counts for 60 s

Efficiency measurement

Final results and uncertainty

OPC bin	$d_{a,i}$	Penetration data reduction			Uncertainty limits		Uncertainty	Efficiency
	μm	P	δ	e	Static	Dynamic	Pass/Fail	%
1	0.35	0.511	0.007	0.009	≤ 0.05	0.036	Pass	48.9
2	0.47	0.424	0.011	0.014	≤ 0.05	0.030	Pass	57.6
3	0.62	0.332	0.014	0.017	≤ 0.05	0.023	Pass	66.8
4	0.84	0.241	0.008	0.010	≤ 0.05	0.017	Pass	75.9
5	1.14	0.126	0.008	0.010	≤ 0.05	0.009	Pass	87.4
6	1.44	0.096	0.014	0.017	≤ 0.05	0.007	Pass	90.4
7	1.88	0.064	0.004	0.005	≤ 0.05	0.004	Pass	93.6
8	2.57	0.021	0.001	0.001	≤ 0.05	0.001	Pass	97.9
9	3.46	0.006	0.001	0.001	≤ 0.05	0.001	Pass	99.4
10	4.69	0.003	0.001	0.001	≤ 0.05	0.000	Pass	99.7
11	6.20	0.003	0.002	0.003	≤ 0.05	0.001	Pass	99.7
12	8.37	0.002	0.002	0.002	≤ 0.05	0.000	Pass	99.8

$d_{a,i}$: Geometric mean diameter of a size range i, μm
P_a: the final penetration for a given particle size
 δ : the standard deviation of the penetration for a given particle size
e: the uncertainty of the penetration for a given particle size

Appendix 5



Fig1. Overview of the test item




Fig 2. Label on the test item

Appendix 6

The interpretation of test reports according to ISO 16890:2016

This brief review of the test procedures, including those for addressing the testing of electrostatic charged filters, is provided for those unfamiliar with the procedures of this series of ISO standards. It is intended to assist in understanding and interpreting the results in the test report/summary. (For further details of procedures the full ISO 16890 document series shall be consulted).

Air filters may rely on the effects of passive static electric charges on the fibres to achieve high efficiencies, particularly in the initial stages of their working life. Environmental factors encountered in service may affect the action of these electric charges so that the initial efficiency may drop substantially after an initial period of service. This could be offset or countered by an increase in efficiency ("mechanical efficiency") as dust deposits build up. The reported, untreated and conditioned (discharged) efficiency shows the extent of the electrical charge effect on initial performance and indicates the potential loss of particle removal efficiency when the charge effect is completely removed and when at the same time there is no compensating increase of the mechanical efficiency. These test results should not be assumed to represent the filter performance in all possible environmental conditions or to represent all possible "real life" behaviour.